CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204953
Address: 3217 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Not Ready	Wednesday, July 07, 2021

Corrective Action Required:

1	Misc	Portal frame approved Ok to cover underside of covered porch

Corrective Action Required:

2	Misc	no erosion control , over grown vegetation. silt fence, gravel, strawl waddles over the curb. install approved silt fence and clean the street.

Comments: