

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203671
Address: 3133 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, July 07, 2021

Corrective Action Required:

1	Misc	-Contact Steve Robbins concerning retaining wall -Obtain lawn irrigation system permit -Final grade and sod -Splash blocks at all downspout and sump pump discharge locations, min 36" from foundation -GFCI protection required at duplex receptacle, dbl car garage bay -Breaker lockouts at all hardwired appliances
---	------	--

Comments: