

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210283
Address: 317 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Wednesday, July 07, 2021

Partial Correction:

1	Misc	GARAGE PORTAL FRAMING OK TO COVER COVERED DECK TRUSSES OK TO COVER FRONT PORCH TRUSSES OK TO COVER OK TO INSTALL HARDIE BOARD SIDING Seal duct at bottom plate master tub Seal top & bottom plate penetrations powder room Provide roof vent at covered deck per plan Provide vertical fire block every 10' bed #3 & bed 4 closet (seal gaps) Provide flashing above horizontal trim @ windows
---	------	--

Comments: