

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20211738	Date:	July 07, 2021
Project Title:	RED DOOR WOODFIRED GRILL	Applicant:	
Location:			
2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081		ELECTRONIC CONTRACTING COMPANY	
Type of Work:		6501 NORTH 70TH ST	
Occupancy Group:	A-2	LINCOLN, NE 68504	
Description:	NEW RESTAURANT		
Construction Type:	Type VB (Unprotected)	Primary:	(402) 466-8274 Ext: MAILING
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Rejected

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
(Informational Purposes)
Call (816)969-1300 to schedule testing.

2. (Action Required)

1. Outside horn/strobe to be located by FDC
2. Add notification devices throughout building.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
(Informational Purposes)
Call (816)969-1300 to schedule testing.

2. (Action Required)

1. Remove outside horn/strobes in patio areas. The only outside horn/strobe needs to be placed by the FDC.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.