

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203845  
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Robb Popp	Partial	Wednesday, July 07, 2021

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	-Conduit from Southwest corner of building north to CT and Transformer location -Conduit for monument sign at Northeast entrance and Left field Musco light at northeast diamond to west end of NE diamond -Conduit for left field Musco light at NW diamond -Conduit from NW dugout electrical room to scoreboards
---	----------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**