

June 18, 2021



P.O. Box 1508
Liberty, Missouri 64069

City of Lee's Summit
220 SE Green Street
Lee's Summit, Missouri 64063


Attn: Building Inspections
Re: Cardinal Crest Homes, Winterset, Lot 1456, 160 NW Carson Drive, Lee's Summit,
Missouri, Permit No. PPRES2021-1467; footing inspection

To whom it may concern:

An inspection was conducted on Friday, June 18, 2021 regarding the above referenced. For reference purposes the house faces east. The 16" wide x 8" thick footing with (2) ½" rebars continuous was installed throughout the garage and basement footing areas. There are (6) building pads for future steel post in the basement and (2) pads in the garage to support the future garage slab. The frost footing is across the rear walkout and 12' ± along the north side. The reinforcing steel was in the forms for the basement and garage footings and pads. The ground rod was installed. The footing and pads were founded on original undisturbed solid clay soil. The concrete contractor, Mid States Form, was given permission to place the concrete into the forms. If you have questions, please contact me at my office.

Sincerely,
Logan & Associates, Inc.

Charles R. Logan, PE
President



cc: Cardinal Crest Homes