

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20204900	Date:	July 07, 2021
Project Title:	WHATABURGER	Applicant:	
Location:	1460 NE DOUGLAS ST, LEES SUMMIT, MO 64086		GOAL FIRE PROTECTION, LLC
Type of Work:			8162 MONTICELLO TER
Occupancy Group:	A-2		SHAWNEE, KS 66227
Description:	NEW FAST FOOD RESTAURANT	Primary:	(913) 441-3390
WITH DRIVE-THRU			
Construction Type:	Type VB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test and a water flow test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.