

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204591  
Address: 107 NW GRADY CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Thursday, July 08, 2021

Corrective Action Required:

1	Misc	Pay not ready fees Irrigation permit #PRIRG20213213 Plot plan notes raise Manhole cover in front left of lot No deck pier inspection on record Provide sod & splash blocks Seal exterior light fixtures Provide Attic access garage per plan Remove construction debris from window well & Expose drain Seal top of meter can, low volt penetrations, gas meter, ac disconnect
---	------	--

Comments: