

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203779
Address: 2334 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Friday, July 09, 2021

Corrective Action Required:

- | | |
|---|--|
| 1 | <ul style="list-style-type: none">*No water connected.*no shower glass.*provide gfci on laundry outlet*provide 1 1/2" clearance to handrail flight to garage level from 1st floor.*bubble cover on front porch outlet.* sod, final grade, gutters splashblocks. exterior incomplete for final inspeciton. |
|---|--|

Comments: