

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20204325  
Address: 4391 SW AMETHYST DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Not Ready	Friday, July 09, 2021

Corrective Action Required:

1	Misc	-Final grade and sod -splash blocks at downspout and sump pump discharge, min 36" discharge from foundation -Built in ovens req for occ, receptacle in cabinet at reinspection with exposed NM -Interconnection required of all smoke detectors- see 2nd floor bedroom S side -cover plates required master bath vanity receptacles -security screws at basement walkout -clip off set screw head on anti siphon, see basement spigot at main water line
---	------	--

**\*\*7/9/21 - INTERIOR ISSUES NOT ADDRESSED AT REINSPECTION, NOT READY FEE ADDED\*\***

**Comments:**