

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20203779  
Address: 2334 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mark Harding	Not Ready	Friday, July 09, 2021

Corrective Action Required:

1

- \*No water connected.
- \*no shower glass.
- \*provide gfci on laundry outlet
- \*provide 1 1/2" clearance to handrail flight to garage level from 1st floor.
- \*bubble cover on front porch outlet.
- \* sod, final grade, gutters splashblocks. exterior incomplete for final inspeciton.

**Comments:**