

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRESRES20204862  
Address: 330 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:     | Outcome: | Date:                 |
|----------------------------|----------------|----------|-----------------------|
| <b>Sidewalk Inspection</b> | Ronald Paynter | Passed   | Friday, July 09, 2021 |

Informational:  
1 Misc 7-6-21 1:09pm Full sun 87 degrees. The forms are set and are ADA compliant at this time. I informed the contractor to use a broom finish and white cure.

Informational:  
2 Misc Finished sidewalk meets LS and ADA specs. RP 7-9-21

**Comments:**