

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRESRES20204862
Address: 330 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Passed	Friday, July 09, 2021

Informational:
1 Misc 7-6-21 1:09pm Full sun 87 degrees. The forms are set and are ADA compliant at this time. I informed the contractor to use a broom finish and white cure.

Informational:
2 Misc Finished sidewalk meets LS and ADA specs. RP 7-9-21

Comments: