

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20211976  
Address: 811 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Mark Harding	Failed	Friday, July 09, 2021

Corrective Action Required:

1 Misc

Multiple permits -  
piers for patio roof was approved for original roof.

Footing was not installed under 6x8 room edge of bar with soda and electrical panel.  
Provide engineering report or design for no frost footing.

**Comments:**