

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204544  
Address: 210 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Not Ready	Monday, July 12, 2021

Corrective Action Required:

1	Misc	-Submit as graded plot plan for review and approval -Sidewalk required per plot plan ( INSPECTION STILL PENDING ) -Final grade and sod -splash blocks at all sump pump and downspout discharge locations, min 36" discharge from foundation -(2) 1/2" through bolts at each post/beam connection -security screws at deck and basement walkout, (2) 3" screws required at each hinge and
---	------	---

**Comments:**