

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204958  
Address: 4404 SW TANZANITE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Patrick Schonfeldt	Failed	Monday, July 12, 2021

Corrective Action Required:  
2 Misc INSPECTION DENIED, CLEAN ALL MUD AND GRAVEL FROM STREET, MAINTAIN  
EROSION CONTROL, GRAVEL FILTER W/ 4" LIFT REQUIRED

**Comments:**