

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210095
Address: 4409 SW TANZANITE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Monday, July 12, 2021

Corrective Action Required:

1	Misc	INSPECTION DENIED, CLEAN ALL MUD AND GRAVEL FROM STREET, MAINTAIN EROSION CONTROL, GRAVEL FILTER W/ 4" LIFT REQUIRED
---	------	--

Comments: