

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204750
Address: 2005 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Tuesday, July 13, 2021

Corrective Action Required:

1	Misc	SIDEWALK INSPECTION STILL PENDING PROVIDE SOD & SPLASH BLOCKS PROVIDE GUTTERS & DOWNSPOUTS Install range hood Land conductors in a box or listed fixture kitchen counters Complete deck & guardrail Provide hardware SGD & secondary lock Remove dust cover smoke detectors Complete stairway spindles Sump discharge 36" from foundation Provide 1 1/2 bearing deck beam Provide clamp on AC whip
---	------	---

Comments: