

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204479
Address: 2357 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Nick Lightner	Partial	Tuesday, July 13, 2021

Informational:
1 Misc 7/13/21 13:38- Rock is placed and has been tamped and the depth of drive is 6in. Good to pour, no contact to the contractor, so they need to make sure they are using the KCM MB 4K mix with the white cure.

Comments: