

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204591
Address: 107 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Not Ready	Wednesday, July 14, 2021

Corrective Action Required:

1	Misc	Pay not ready fees Irrigation permit #PRIRG20213213 Plot plan notes raise Manhole cover in front left of lot Provide sod & splash blocks Seal exterior light fixtures Provide Attic access garage per plan Remove construction debris from window well & Expose drain Seal top of meter can, low volt penetrations, gas meter, ac disconnect
---	------	---

Comments: