

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	Robb Popp	Partial	Wednesday, July 14, 2021

Informational:

1	Miscellaneous Correction	Componenets bonded: Shell bonding, (4) points, perimeter surface, sleeves for accessible device, ladder, bond to equipment location Water bonding to be in line at pump
---	--------------------------	---

Comments: