

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212613
Address: 2050 NW LOWENSTEIN DR, Unit:C, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Partial	Wednesday, July 14, 2021

Corrective Action Required:

1	Misc	- ELECTRIC APPROVED -
---	------	-----------------------

FIRE CAULK GAS LINES AT TOP PLATE PENETRATION
SCHEDULE PLUMBING & MECHANICAL INSPECTIONS BEFORE COVERING

Comments: