

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20204544
Address: 210 NW JOSHUA DR, LEES SUMMIT, MO 64081
Inspected On: Wednesday, July 14, 2021
Inspected By: Michael Harkins
Expiration Date: 08/13/2021

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Wednesday, July 14, 2021

Corrective Action Required:

1	Misc	-Sidewalk required per plot plan (INSPECTION STILL PENDING) -Final grade and sod -splash blocks at all sump pump and downspout discharge locations, min 36" discharge from foundation -(2) 1/2" through bolts at each post/beam connection - PLOT PLANS SHOWS MANHOLE AT CURB & SIDEWALK - SEWER TRACER WIRE IN BOX AT GRADE - PAY NOT READY FEE
---	------	--