CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738

Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Footing Inspection - Michael Harkins Partial Wednesday, July 14,

Commercial 2021

Corrective Action Required:

1 THE FOLLOWING - LINE H 2 TO 7, LINE 7 H TO D, LINE 2 H TO D -

AREAS ARE - LINE D 2 TO LINE A 2 , LINE 6 TO A LINE, UFER LOCATED MIDDLE WEST WALL -

APPROVED - LINE 7 A TO H -

- (3) COLUMN PADS C LINE WEST END -

Comments: