

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204075
Address: 1920 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Nick Lightner	Passed	Thursday, July 15, 2021

Informational:
1 Misc 7/12/21 14:00 depth is correct, rock has been placed and crew is carrying percent of fail for the ada through the sidewalk.

Informational:
2 Misc 7/15/21 7:40- Drive and curb are correct. Drive is carrying a 1.5% through the sidewalk.

Comments: