

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204325  
Address: 4391 SW AMETHYST DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Thursday, July 15, 2021

Corrective Action Required:

1	Misc	-Obtain lawn irrigation system permit -splash blocks at downspout and sump pump discharge, min 36" discharge from foundation -Uncover manhole at rear corner of lot as shown on plot plan
---	------	---

**\*\*OK FOR TCO - TCO EXPIRES 7/28/21\*\***

**Comments:**