

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204535
Address: 2029 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Thursday, July 15, 2021

Corrective Action Required:

2	Miscellaneous Correction	Nail sheathing throughout per code / per plan sheet S1.0 (! East garage wall, bed #2, great room) Provide CF PF nailing great room window Fire block dead space laundry (seal gaps) Fire block dead space near SGD basement (!seal at DWV) Fire block east wall top plate to roof deck (seal gaps
---	--------------------------	---

: DO NOT INSULATE :

Comments: