

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204103
Address: 129 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Passed	Thursday, July 15, 2021

Informational:
1 Misc -Grounding electrode Conductor connection to concrete encased electrode to remain accessible
(IN POCKET CLOSET OF BEDROOM WITH SERVICE PANEL)

Comments: