CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204525

Address: 111 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Sidewalk Inspection Ronald Paynter Passed Friday, July 16, 2021

Informational:

1 Misc Forms were placed and aggregate was present and compacted. RP 7-7-21

Informational:

2 Misc Finished sidewalk meets LS and ADA specs. RP 7-16-21

Comments: