

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210266
Address: 2112 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Passed	Friday, July 16, 2021

Corrective Action Required:

1	Misc	Doesn't have the required depth of aggregate. RP 7-8-21
Informational:		
2	Misc	Forms were placed and aggregate was present and compacted. RP 7-9-21
Informational:		
3	Misc	Finished driveway meets LS and ADA specs. RP 7-16-21

Comments: