

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20212466
Address: 508 SE DAVID RD, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Mark Harding	Failed - Stop Work	Friday, July 16, 2021

Corrective Action Required
1 Misc

3rd Party inspection denied.
No address, no erosion control, no construction entrance.
Stop Construction issued.
False engineers report stating erosion controls is in place. David Ainsworth PE.

Corrective Action Required
2 Misc

Do not pour foundation until erosion control and construction entrance is in place and re-inspected.

Comments: