

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202637
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Friday, July 16, 2021

Informational:

1	FIRST FLOOR	**AREAS APPROVED**
---	-------------	--------------------

-SHAFT LAYER AT BUILDING A/B SEPARATION WALL BOTH SIDES

Corrective Action Required:

2	Miscellaneous Correction	-COMPLETE SCREW PATTERN AT SHAFT WALL BLD. A -SEAL PENETRATIONS IN SECOND LAYER
---	-----------------------------	--

Comments: