

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20203515

Address: 2608 SW WARD RD, LEES SUMMIT, MO 640822600 SW WARD RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Mark Harding	Partial	Friday, July 16, 2021

Informational:

1	Misc	Visitors concession/restrooms only - partial approval of plumbing and electrical. Plumbing in concealed chases approved to ceiling level. Electrical conduit in CMU walls approved up to 8 blocks in height
---	------	---

Corrective Action Required:

2	THIRD FLOOR	PRESS BOX 3RD FLOOR-
		STORAGE WALL OK TO ONE SIDE W1-302
		NORTH EXTERIOR WALL OK TO COVER W1-S3

Comments: