

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20211738  
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Michael Harkins	Partial	Monday, July 19, 2021

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | - LINE H 2 TO 7, LINE 7 H TO D, LINE 2 H TO D -<br>- LINE D 2 TO LINE A 2 , LINE 6 TO A LINE, UFER LOCATED MIDDLE WEST WALL -<br>- LINE 7 A TO H -<br>- (3) COLUMN PADS C LINE WEST END -<br>- (3) COLUMN PADS EAST SIDE, (3) PIERS SW CORNER -<br>- (4) PIERS SW CORNER - |
|---|------|--|

**Comments:**