

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204953
Address: 3217 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, July 19, 2021

Corrective Action Required:

1	Misc	-Strap top plates bedroom 3, less than 24 inches lap. -seal top plate penetration at 2nd floor laundry DWV, fireblock DWV chase at closet -Install rafter ties in lower third of rafter span over front bedroom from LVL to front wall.
---	------	---

Comments: