

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204536
Address: 110 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Monday, July 19, 2021

Corrective Action Required:

1	Misc	-Provide (2) through bolts at beam to post connections per code - PAY OUTSTANDING FEES - - SUBMIT BACKFLOW CERTIFICATION - Provide sod & splash blocks Sump discharge 36" from foundation Remove dust covers from smoke detectors Provide two 3" screws in each exterior hinge & db strike plate Provide through bolts deck beam Address 6x6 cedar post not continuous per plan Seal exterior penetrations, top of meter can, AC disconnect, top of light fixtures, gas line
---	------	---

Comments: