



HD ENGINEERING & DESIGN, INC

11656 W. 75TH STREET
SHAWNEE, KS 66214

WWW.HDENGINEERS.COM


913.631.2222

SERVICE@HDENGINEERS.COM

CARDINAL CREST HOMES
Scout 3 Bdrm Spec
1036 SW Armie St, KC, MO

Our firm has been asked to make a structural recommendation for the house being built at the address listed above. The builder has informed us that during the rough in inspection the city has questioned the wall bracing behind the tub/shower insert.

After reviewing this item our firm recommends screwing the opposite side of the wall with the GB method as shown on the approved plans. The GB bracing should extend as shown on the sketch attached.



STRUCTURAL REVIEW
HD ENGINEERING & DESIGN
HD: 40013 DATE: 7/14/2021