

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200773  
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Failed	Tuesday, July 20, 2021

Informational:

1	Miscellaneous Correction	-CORRIDOR WALLS OF 1 HOUR STORAGE ROOM OK
---	-----------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	-COMPLETE SCREW PATTERN AT SHAFT WALL IN STORAGE
---	-----------------------------	--

**Comments:**