

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204748
Address: 1516 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, July 20, 2021

Corrective Action Required:

1	Misc	-Install basement egress window -DWV bored at joist less than 2" from top of joist- see W side basement, replace or submit engineered letter -NO ENGINEER LETTER IN PERMIT? REQUIRED FOR FIELD FIX -CS-PF at great room windows per plans and R602.10.6.4, nail pattern at band/rim joist
---	------	---

Comments: