

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212082
Address: 1100 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Not Ready	Tuesday, July 20, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide bonding screw metal boxes Fire caulk upward penetrations Provide midpoint support vertical DWV 2" & smaller Provide boca plates DWV
---	-----------------------------	---

Comments: