

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204751
Address: 2017 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Steve Robbins	Partial	Tuesday, July 20, 2021

Informational:	
1 Misc	Sidewalk was formed and rock was compacted. Also made them clean up in front of the house before passing the pre-pour. The forms appear to meet ADA standards.

Comments: