

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210124
Address: 1526 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, July 20, 2021

Corrective Action Required:

1	Misc	-Firestop attic space -along kitchen/great room wall(seal gaps at fireblock), -24" offset required required at dbl top plate breaks, strap top plate- basement den windows
---	------	--

Comments: