

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204780
Address: 2025 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------|---------------|----------|------------------------|
| Sidewalk Inspection | Steve Robbins | Partial | Tuesday, July 20, 2021 |

| | |
|----------------|--|
| Informational: | |
| 1 Misc | Sidewalk was formed and rock was compacted. Also made them clean up in front of the house before passing the pre-pour. The forms appear to meet ADA standards. |

Comments: