

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|-----------------|----------|------------------------|
| Footing Inspection - Commercial | Michael Harkins | Partial | Tuesday, July 20, 2021 |

Corrective Action Required:

- | | | |
|---|----------------------------------|--|
| 1 | THE FOLLOWING AREAS ARE APPROVED | - LINE H 2 TO 7, LINE 7 H TO D, LINE 2 H TO D - - LINE D 2 TO LINE A 2 , LINE 6 TO A LINE, UFER LOCATED MIDDLE WEST WALL - - LINE 7 A TO H - - (3) COLUMN PADS C LINE WEST END - - (3) COLUMN PADS EAST SIDE, (3) PIERS SW CORNER W/ (6) # 5 VERT W/ # 4 WRAP @ 8" OC - - PATIO FIREPLACE FOOTING - |
|---|----------------------------------|--|

Comments: