

July 20, 2021

Summit Homes 120 SE 30th St. Lee's Summit, MO 64082

RE: Field Issue deck beam attachment and non-continuous post for Lot #6 Woodside Ridge – 110 NW Grady Ct. Lee's Summit. MO 64081 – Permit # PRRES20204536

This letter addresses the deck beam attachment and non-continuous post for Lot #6 Woodside Ridge.

The revision shall be as follows:

- Install (2) 1/4" x 6" lag screws per deck beam to post connection.
- Install screw head at inner edge of post to extend outward into deck beam and trim piece.
- Deck post is notched 2 ply for 2 ply deck beam.
- Install 16-ga. ST12 Simpson galvanized strap on each post per manufacturer's specifications.
- Install with (10) .162 x 2-1/2 nails or approved Simpson SD screws per manufacturer's specs.
- Straps shall be centered over post cut.
- Many of these products are approved for installation with Strong-Drive® SD Connector screws.

Model No.	Ga.	Dimensions (in.)		Fasteners (Total) (in.)	Allowable Tension Loads (DF/SP)	Allowable Tension Loads (SPF/HF)
		W	L		(160)	(160)
ST2115	20	3/4	16%	(10) 0.162 x 21/2	660	660
ST9	- 16	11/4	9	(8) 0.162 x 21/2	885	765
ST12		11/4	11%	(10) 0.162 x 2½	1,105	955
ST18		11/4	173/4	(14) 0.162 x 21/2	1,420	1,335
ST22		11/4	21%	(18) 0.162 x 21/2	1,420	1,420
ST292	20	21/16	9%	(12) 0.162 x 21/2	1,260	1,120
ST2122		21/16	1213/16	(16) 0.162 x 21/2	1,530	1,510
ST2215		21/16	16%	(20) 0.162 x 21/2	1,875	1,875
ST6215	16	21/16	16%	(20) 0.162 x 21/2	2,090	1,910
ST6224		21/16	23%6	(28) 0.162 x 21/2	2,535	2,535
ST6236	14	21/16	33134e	(40) 0.162 x 21/2	3,845	3,845

^{1.} See General Notes for Straps and Ties.

Sincerely,

Bradley Huxol, PE

Fasteners: Nail dimensions in the table are listed diameter by length. For additional information, see <u>Fastener Types and Sizes Specified for Simpsor</u> Strong-Tie Connectors.