

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203515

Address: 2608 SW WARD RD, LEES SUMMIT, MO 640822600 SW WARD RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Morris	Failed	Tuesday, July 20, 2021

Corrective Action Required:

1 Misc

2nd floor press building:

- provide detail on track support for hard ceiling.
- install all whips and MC , ssecure within 12" of box or if MC is over 6' whip.
- missing knock out on 4x4 box north wall.

**Comments:**