

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20212095  
Address: 3544 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Patrick Schonfeldt	Failed	Tuesday, July 20, 2021

Corrective Action Required:

1	Misc	--7/20/21 - PARTIAL INSPECTION IN WALL PLUMBING ONLY -SECURE VERTICAL DWV 2" OR LESS AT MID POINT -BOCCA PROTECTION PLATES REQ AT TOP AND BOTTOM PLATE DWV, PROTECTION REQ FOR PLATE AND 2" ABOVE OR BELOW
---	------	---

**Comments:**