

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210350
Address: 1425 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, July 21, 2021

Corrective Action Required:

1	Misc	-Fireblock chases at great room windows see right side above HVAV and DWV -Protection required of flex gas line at fireplace entrance also secure gas line at fireplace -land electrical to box hanging from ceiling at dining room windows and foyer -All truss hangers per plans-see garage -CS-PF design including nail pattern per plans at great room windows -strap 2x6 to 2x4 top plates at top 2nd floor stairs -see above foyer side as well
---	------	--

Comments: