CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204450

Address: 2013 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Michael Harkins Failed Tuesday, June 08, 2021

Residential

Corrective Action Required:

1 Misc Provide 1 1/2 bearing deck beam

OR

LEDGER LOCK SIDES TO HOUSE PER CODE AND USE SIMPSON CONCEALED

FLANG DOUBLE JOIST HANGER HUC212-2 OR EQUIVALENT

: Ok to insulate :

Comments: