

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212657

Address: 940 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:F, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:B, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:C, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:D, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:E, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:G, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:H, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:I, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:J, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:K, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:P, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:L, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:M, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:N, LEES SUMMIT, MO 64081940 NW PRYOR RD, Unit:O, LEES SUMMIT, MO 64081940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Partial	Wednesday, July 21, 2021

Informational:

1 Misc

UNIT G
METAL STUD FRAMING OK TO INSULATE / ROCK
UNIT A & B
METAL STUD FRAMING 1 HOUR WALL OK TO ROCK

Comments: